

July 21, 2026

Fire Chief Patterson
Clallam County Fire District 2

Fire Chief Patterson,

Washington Surveying and Rating Bureau (WSRB) has completed its evaluation of your community's fire protection capabilities as they relate to fire insurance rating.

We wish to inform you that the Protection Class (PC) for Clallam County Fire District 2 has remained a Protection Class 6.

A PC 6 rating applies to dwelling and commercial properties located in the community within five road miles of a responding fire station that has standard fire hydrant distribution and water supply. Properties in the community that do not meet these requirements will receive a different PC rating.

PC ratings for individual dwelling and commercial properties are available by calling WSRB Customer Service at 206-217-0101 or emailing customerservice@wsrb.com.

Clallam County Fire District 2 was also evaluated for WSRB Tender Credit, and it was determined that the community will retain this PC rating credit.

We wish to thank you for the cooperation during the evaluation process. Accompanying this letter is a copy of the new Protection Class Report detailing the various items evaluated and the credit attained for each item.

Please note that WSRB evaluations aren't conducted for property loss prevention or life safety purposes. Rather, they are intended to gather information needed to determine a fire insurance relevant PC which may be used to develop fire insurance rates or loss costs. Our evaluation criteria incorporate many nationally recognized standards, including those developed by NFPA, ICC and AWWA.

Thank you for your time and cooperation. If you have any questions, please let us know.

Sincerely,

A handwritten signature in blue ink, appearing to read 'JS', is positioned above the printed name of Jason Sanders.

Jason Sanders
Fire Protection Analyst II
206-273-7148
jason.sanders@wsrb.com